



Certificate of Compliance

Certificate: 2644203

Master Contract: 164460

Project: 2644203

Date Issued: January 24, 2014

Issued to: EGS Electrical Group LLC

9377 W Higgins Rd
Rosemont, IL 60018
USA

Attention: Leonard Steinbeigle

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Don Verbeem

Issued by: Don Verbeem

PRODUCTS

CLASS 4658 01 - SWITCHES - Miscellaneous - For Hazardous Locations

CLASS 4658 81 - SWITCHES-Miscellaneous - For Hazardous Locations-Certified to U.S. Standards

- **2- 8 pole rotary actuated switch – Series US 16**

Canadian Ratings

Class I, Division 2, Groups A, B, C, and D; T6

Ex de IIC; T6

United States Ratings

Class I, Division 2, Groups A, B, C, and D; T6

Class I, Zone 1, AEx de IIC; T6



Certificate: 2644203

Master Contract: 164460

Project: 2644203

Date Issued: January 24, 2014

Accepted ambient -55°C to 80°C

Electrical Ratings

AC General Use Switch: 600Vac, 20A

DC General Use Switch: 125Vdc, 10A

AC Control Circuit Contact: A600 (600V Heavy Duty)

DC Control Circuit Contact: N150

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-12 – General Requirements – Canadian Electrical Code, Part II

C22.2 No. 14-10 – Industrial Control Equipment

C22.2 No. 213-M1987 – Non-incendive Electrical for Use in Class I, Division 2 Hazardous Locations

CSA C22.2 No. 60079-0 – Electrical apparatus for explosive gas atmospheres – Part 0: General Requirements

CSA C22.2 No. 60079-1 – Electrical apparatus for explosive gas atmospheres – Part 1: Flameproof Enclosures “d”

CSA C22.2 No. 60079-7 – Electrical apparatus for explosive gas atmospheres – Part 7: Equipment protection by increased safety “e”

UL 508, 17th Ed – Standard for Industrial Control Equipment

ANSI /ISA12.12.01, 12th Ed – Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

UL 60079-0, 5th Ed – Electrical apparatus for explosive gas atmospheres – Part 0: General Requirements

UL 60079-1, 6th Ed – Electrical apparatus for explosive gas atmospheres – Part 1: Flameproof Enclosures “d”

UL 60079-7, 4th Ed – Electrical apparatus for explosive gas atmospheres – Part 7: Equipment protection by increased safety “e”